

### ALBERTA ELECTRICAL UTILITY CODE

**SUBJECT: Errata to the Alberta Electrical Utility Code, 4<sup>th</sup> Edition, 2013**

The following is a list of errata that have been identified in the 2013 edition of the Alberta Electrical Utility Code.

**Appendix A, Rule 4-134(b)** – "...limits of approach distances required by Rule 2-012 and Table 5-1 shall be used." should read "...limits of approach distances required by Rule 2-014 and Table 1 shall be used."

**Appendix C Note to Rule 5.3.1.1** – "Note 6 of Table 5 has been added to reflect the Canadian Electrical Code clearance requirements of Clause 6-112(d)." should read "Note 6 of Table 5 has been added to reflect the Canadian Electrical Code clearance requirements of Rule 6-112(2)(d)."

**Appendix C, page 78, fifth row down** – "(Note that Table A.1 of the CSA document shows 15806 mm)" should read: "(Note that Table A.1 of the CSA document shows 1580.6 mm)"